



NOTES:

1. COORDINATE EXACT LOCATION OF VAV UNIT CONTROL ENCLOSURES WITH OTHER TRADES. REFER TO FLOOR PLANS AND REVISE PLAN DRAWING LOCATIONS AS NECESSARY TO AVOID CONFLICTS.

VAV UNIT WITH "STO" CONNECTION & TLM

NOT TO SCALE