

SUBMITTAL DATA

Flexmaster U.S.A.® Vapor Barrier



(B) Black Polyethylene Vapor Barrier

(M) Reinforced Silver Mylar Vapor Barrier

Technical Data		
Vapor Barrier	(B) Black Rip-Stop Polyethylene	(M) Reinforced Silver Mylar
Material Components	flame retardant Polyethylene	metalized and clear polyester film, fiberglass scrim, flame retardant adhesive
Vapor Barrier Permeance	B - (.10) perm, A.S.T.M. E96, Procedure A	M - (.05) perm, A.S.T.M. E96, Procedure A
Test Standard	UL181	UL181
Tested By	Intertek/ETL	Intertek/ETL
Certifications Met	Class 1 Air Duct, NFPA 90A and 90B, BOCA, SBBC, HUD/FHA, MIN Property Std.	Class 1 Air Duct, NFPA 90A and 90B, BOCA, SBBC, HUD/FHA, MIN Property Std.
Rated Velocity	5500 F.P.M.	5500 F.P.M.
Operating Temperature Range	-20° to +250°F	-20° to +250°F
Flame/Smoke	25/50	25/50

Flexmaster U.S.A.®
 5235 Ted Street
 Houston, TX 77040 USA
 Tel. +1.713.462.7694
 Fax +1.713.939.8441
www.FlexmasterUSA.com
www.Masterduct.com

 **FLEXMASTER U.S.A.®**
 A MASTERDUCT COMPANY